627 RIVERBANK DRIVE GENEVA, IL 60134 630-232-0104

Test Report

www.riverbankacoustics.com

Sound Absorption RALTM-A24-163

FOUNDED 1918 BY WALLACE CLEMENT SABINE

Page 1 of 9

SPONSOR: Moxie Surfaces

Encinitas, CA

CONDUCTED: 2024-03-22

ON: AIR-board Acoustic - 1" with edging (4 rows of 2 units each, rows spaced 30" on center, units in rows spaced 12" apart)

TEST METHODOLOGY

Riverbank Acoustical Laboratories[™] is accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) as an ISO 17025:2017 Laboratory (NVLAP Lab Code: 100227-0) and for this test procedure. The test reported in this document conformed explicitly with ASTM C423-23: "Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The specimen mounting was performed according to ASTM E795-23: "Standard Practices for Mounting Test Specimens During Sound Absorption Tests." A description of the measurement procedure and room specifications are available upon request. The results presented in this report apply to the sample as received from the test sponsor.

INFORMATION PROVIDED BY SPONSOR

The test specimen was designated by the sponsor as AIR-board Acoustic - 1" with edging (4 rows of 2 units each, rows spaced 30" on center, units in rows spaced 12" apart). The following nominal product information was provided by the sponsor prior to testing. The accuracy of such sponsor-provided information can affect the validity of the test results.

Product Under Test

Product Name:AIR-board Acoustic – 1"Manufacturer:Design CompositeUS Distributor:Moxie Surfaces

SPECIMEN MEASUREMENTS & TEST CONDITIONS

Through a full external visual inspection performed on the test specimen, Riverbank personnel verified the following information:

Test Specimen

Material:Panels, honeycomb core and microperforated sheets on face and back
Panel edges sealed with solid materialDimensions:8 panels @ 610 mm (24 in.) by 1219 mm (48 in.)Thickness:24.94 mm (0.982 in.)Overall Weight:25.4 kg (56 lbs)



(B) RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces 2024-03-22

Test Report

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RALTM-A24-163

Page 2 of 9

Physical Measurements (per object)

Dimensions:	0.61 m (24.0 in) wide by 1.22 m (48.0 in) long
Thickness:	0.02 m (0.982 in)
Weight:	3.18 kg (7.0 lbs)

Test Environment

Room Volume:	291.98 m ³
Temperature:	21.4 °C \pm 0.2 °C (Requirement: \geq 10 °C and \leq 5 °C change)
Relative Humidity:	$62.2 \% \pm 2.8 \%$ (Requirement: $\ge 40 \%$ and $\le 5 \%$ change)
Barometric Pressure:	99.0 kPa (Requirement not defined)

Each sound absorbing object had an exposed surface area of 1.58 m^2 (17.0 ft²). The total exposed surface area of all sound-absorbing objects was 12.6 m² (136 ft²).

MOUNTING METHOD

Type JV Mounting: The specimen is an array of 8 spaced sound absorbing objects suspended from cables vertically such that the closest face is located approximately 768 mm (30.25 in.) from the horizontal test surface. This approximates the mounting method of a typical ceiling baffle installation. The objects were distributed in four rows of two objects each, with rows spaced 30" on center, and units in rows spaced 12" apart. The width of the installed object array was 2324 mm (91.5 in.) and the length of the installed object array was 2743 mm (108 in.). The area of extended continuous surface attributed to the object array was 9.33 m² (100 ft²).



RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces 2024-03-22

Test Report

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RALTM-A24-163 Page 3 of 9



Figure 1 – Specimen mounted in test chamber




Figure 2 – Detail of specimen material



®RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE NVLAP LAB CODE 100227-0 SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces 2024-03-22

Test Report

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RALTM-A24-163 Page 4 of 9



Figure 3 – Detail of specimen materials



®RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE NVLAP LAB CODE 100227-0 SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

Test Report

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces 2024-03-22

TEST RESULTS

The preferred presentation of sound absorption test results for arrays of spaced objects is sound absorption (m^2) per object and total sound absorption (m^2) at each one-third-octave band

ASTM C423-23 Appendix X2 allows calculation of sound absorption per m^2 (SA/m²) based on the projected horizontal surface area attributable to an array of objects. The extended continuous surface area used in this calculation is to be determined using the following procedure:

 $S_{array} = (w + w_1) \times (l + l_1)$ If the set of objects consists of a rectangular array of equal sized objects with equal space between each object in a row and equal space between rows. (ASTM E423-23 X.2.3.1)

Where:

 S_{array} = area of extended continuous surface attributed to the test specimen, m² w = the measured width of the installed object array, in meters w_l = the space between objects in the array along the width, in meters l = the measured length of the installed object array, in meters l_l = the space between objects in the array along the length, in meters

The sound absorption per m^2 (SA/m²) is calculated based on the following formula:

$$\alpha_{array} = (A_2 - A_1)/S_{array}$$

Where:

 α_{array} = sound absorption per m² (SA/m²) of extended continuous surface, no units, A₁ = absorption of the empty reverberation room, m² and A₂ = absorption of the room after the specimen has been installed, m². S_{array} = area of extended continuous surface attributed to the test specimen, m²



©RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RAL[™]-A24-163 Page 5 of 9

Test Report

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces

2024-03-22

TEST RESULTS (continued)

1/3 OctaveTotal AbsorpCenter FrequencyTotal Absorp		bsorption	ption Absorption per Object		
(Hz)	(m ²)	(Sabins)	(m ² /Object)	(Sabins / Object)	(Sabins/ft ²) (SA/m ²)
100	1.00	10.75	0.12	1.34	0.11
** 125	0.85	9.14	0.11	1.14	0.09
160	1.00	10.71	0.12	1.34	0.11
200	1.15	12.37	0.14	1.55	0.12
** 250	1.42	15.25	0.18	1.91	0.15
315	1.53	16.47	0.19	2.06	0.16
400	1.60	17.23	0.20	2.15	0.17
** 500	1.80	19.39	0.23	2.42	0.19
630	1.98	21.26	0.25	2.66	0.21
800	2.31	24.89	0.29	3.11	0.25
** 1000	2.86	30.77	0.36	3.85	0.31
1250	3.64	39.18	0.45	4.90	0.39
1600	5.32	57.24	0.66	7.15	0.57
** 2000	6.80	73.22	0.85	9.15	0.73
2500	6.61	71.16	0.83	8.90	0.71
3150	5.34	57.44	0.67	7.18	0.57
** 4000	4.32	46.55	0.54	5.82	0.46
5000	3.46	37.26	0.43	4.66	0.37

Array-NRC 0.35 over 9.33 m² of extended continuous surface area Array-SAA 0.33 over 9.33 m² of extended continuous surface area

Tested by Report by Approved by 11 Marc Sciaky Eric P. Wolfram Keith Kimberling Senior Experimentalist Test Engineer Laboratory Manager

Note: Sound absorption per m^2 (SA/ m^2), and therefore the reported Single Number Ratings, are highly dependent on the exact sample shape, size, spacing, and extended continuous surface area present in the test and subsequent calculations. Changes to any of these parameters will change the resulting values. These presented results are valid only for the specific configuration present in this test.



®RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE NVLAP LAB CODE 100227-0 SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RAL™-A24-163

Page 6 of 9

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces 2024-03-22

Test Report


www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RALTM-A24-163 Page 7 of 9

SOUND ABSORPTION REPORT

AIR-board Acoustic - 1" with edging (4 rows of 2 units each, rows spaced 30" on center, units in rows spaced 12" apart)



Array-NRC 0.35 over 9.33 m^2 of extended continuous surface area Array-SAA 0.33 over 9.33 m^2 of extended continuous surface area



[®]RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

Test Report

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Moxie Surfaces 2024-03-22

APPENDIX A: Extended Frequency Range Data

Specimen: AIR-board Acoustic - 1" with edging (4 rows of 2 units each, rows spaced 30" on center, units in rows spaced 12" apart) (See Full Report)

The following non-accredited data were obtained in accordance with ASTM C423-23, but extend beyond the defined frequency range of 100Hz to 5,000Hz. These unofficial results are representative of the RAL test environment only and intended for research & comparison purposes.

1/3 Octave Band Center Frequency	Total Absorption		Absorption per Object		α _{array} (Sabins/ft ²)
(Hz)	(m ²)	(Sabins)	(m ² /Object)	(Sabins / Object)	(SA/m^2)
31.5	3.12	33.62	0.39	4.20	0.33
40	1.16	12.47	0.14	1.56	0.12
50	0.03	0.29	0.00	0.04	0.00
63	0.50	5.34	0.06	0.67	0.05
80	0.94	10.11	0.12	1.26	0.10
100	1.00	10.75	0.12	1.34	0.11
125	0.85	9.14	0.11	1.14	0.09
160	1.00	10.71	0.12	1.34	0.11
200	1.15	12.37	0.14	1.55	0.12
250	1.42	15.25	0.18	1.91	0.15
315	1.53	16.47	0.19	2.06	0.16
400	1.60	17.23	0.20	2.15	0.17
500	1.80	19.39	0.23	2.42	0.19
630	1.98	21.26	0.25	2.66	0.21
800	2.31	24.89	0.29	3.11	0.25
1000	2.86	30.77	0.36	3.85	0.31
1250	3.64	39.18	0.45	4.90	0.39
1600	5.32	57.24	0.66	7.15	0.57
2000	6.80	73.22	0.85	9.15	0.73
2500	6.61	71.16	0.83	8.90	0.71
3150	5.34	57.44	0.67	7.18	0.57
4000	4.32	46.55	0.54	5.82	0.46
5000	3.46	37.26	0.43	4.66	0.37
6300	2.85	30.63	0.36	3.83	0.31
8000	3.93	42.31	0.49	5.29	0.42
10000	5.58	60.11	0.70	7.51	0.60
12500	3.80	40.87	0.47	5.11	0.41

TESTING

®RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE NVLAP LAB CODE 100227-0 SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RAL™-A24-163

Page 8 of 9

627 RIVERBANK DRIVE GENEVA, IL 60134

630-232-0104

Test Report

www.riverbankacoustics.com

FOUNDED 1918 BY WALLACE CLEMENT SABINE

RAL™-A24-163

Page 9 of $\overline{9}$

Moxie Surfaces 2024-03-22

APPENDIX B: Instruments of Traceability

Specimen: AIR-board Acoustic - 1" with edging (4 rows of 2 units each, rows spaced 30" on center, units in rows spaced 12" apart) (See Full Report)

		Serial	Date of	Calibration
Description	Model	<u>Number</u>	Certification	Due
System 1	Type 3160-A-042	3160- 106968	2023-07-17	2024-07-17
Bruel & Kjaer Mic And Preamp G	Type 4943-B-001	2525858	2023-05-03	2024-05-03
Bruel & Kjaer Pistonphone EXTECH Hygro 6015	Type 4228 SD700	2781248 A.116015	2023-07-12 2023-05-31	2024-07-12 2024-05-31

APPENDIX C: Revisions to Original Test Report

Specimen: AIR-board Acoustic - 1" with edging (4 rows of 2 units each, rows spaced 30" on center, units in rows spaced 12" apart) (See Full Report)

<u>Date</u>	Revision
2024-04-08	Original report issued

END



®RIVERBANK ACOUSTICAL LABORATORIES IS ACCREDITED BY NVLAP (LAB CODE 100227-0) FOR ACOUSTICAL TESTING SERVICES IN ACCORDANCE WITH ISO/IEC 17025:2017 AND FOR THIS PROCEDURE. THIS REPORT MUST NOT BE USED BY THE CLIENT TO CLAIM PRODUCT CERTIFICATION, APPROVAL, OR ENDORSEMENT BY RAL, NVLAP, NIST, OR ANY AGENCY OF THE U.S. GOVERNMENT. THIS REPORT SHALL NOT BE MODIFIED WITHOUT THE WRITTEN APPROVAL OF RAL. THE RESULTS REPORTED APPLY ONLY TO THE NVLAP LAB CODE 100227-0 SPECIFIC SAMPLE SUBMITTED FOR TESTING; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SAMPLE.